



CERTIFICATE n° 03-118-6 SGWA

Certificate Holder: SERTO AG, CH-8500 Frauenfeld
Manufacturer: SERTO AG, CH-8500 Frauenfeld
Representative / Distributor: SERTO AG, CH-8500 Frauenfeld

In accordance with our regulation ZG101 „General terms and conditions of the SGWA certification body gas“ and the report No. **03-118-6** the SGWA certify the following serial products:

Rubric: Connections, Pipe couplings
Designation: Removable unions for metal tubes SERTO SO
Types:

G (Ms) SO	03-118-6/1
M (Ms) SO	03-118-6/2
M (SS) SO	03-118-6/3

see type list on page 2

Certification Standard: DIN 3387-1 (2008)
Nominal diameter: DN 6 – 25 (Type G (Ms) SO), DN 6 – 32 (Type M (Ms) SO), DN 6 – 32 (Type M (SS) SO)
Connection: Connection for smooth ends, thread according to EN 10226-1
Validity: 31.12.2028
Certified for:

- Maximum operating pressure of 5 bar in the distribution grid
- Maximum operating pressure of 16 resp. 25 bar for industrial installations without threads according EN 10226-1
- Tubes of metal with smooth ends
- Natural gas and liquefied gas in the gas phase
- Ambient temperature between -20°C and +60°C

The applicant is therefore allowed to offer these products as SGWA-certified and to use the SGWA conformity label (publication in the online gas certification listing gas ZIS Gas).



accredited according to:
SN EN ISO/IEC 17065

SWISS GAS AND WATER INDUSTRY ASSOCIATION

Certification body gas

Javier Fernandez
Chef